

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Hunter's Run Subdivision	<b>Date</b> 3-18-2020
<b>Location</b> Hunter's Run, Horeseheads (T), NY	<b>Permit #</b> NYR11F984
<b>Weather Conditions</b> overcast, mild	<b>Entry Time:</b> 2:10 pm
<b>On-Site Representative Present:</b> none	<b>Exit Time:</b> 2:20 pm

Construction Site Notes:			
-No active earthwork is being done at this time.			

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X	X		Have stabilization measures been initiated in inactive areas	<b>SEE NOTE</b>
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
X			Are the inspections being performed by a qualified individual?	

Corrections Needed:			
-Catch basin in front of the house under construction is buried by stone. You can barely make out that a drainage structure is located here. The stone material covering catch basin needs to be removed, the drainage structure needs to be inspected and cleaned out to ensure it is functioning and drop inlet protections are to be added.			
-Stabilization of soil around the house that is constructed is required. Whether it is temporary or permanent, it is needed.			

Satisfactory	Marginal	XX	Unsatisfactory
<b>Date</b> 3-18-2020	<b>Inspector</b> <i>Jessica Verrigni</i>		



**COUNTY OF CHEMUNG**  
**Chemung County Stormwater Coalition**  
**851 Chemung Street**  
**Horseheads, New York 14825**  
**Ph. 607.796.2216**

**PROJECT:** Hunter's Run  
Town of Horseheads  
Municipal Inspection  
March 18, 2020

**BY:** Jessica Verrigni, CPESC, CPSWQ



Construction entrance is working order.



House lot that is under construction needs stabilization. The catch basin at the front of the house has been buried in stone.



Only a small portion of this drainage structure is seen. Stone needs to be removed and proper inlet protection is to be installed.



All open soil, except the house, has been stabilized.