

**Chemung County Stormwater  
Construction Inspection  
Erosion and Sediment Control**



<b>Project Name</b> Hunter's Run	<b>Date</b> 6-10-20
<b>Location</b> Steeple Chase Horseheads, NY	<b>Permit #</b> NYR11F984
<b>Weather Conditions</b> sunny warm	<b>Entry Time:</b> 8:56 am
<b>On-Site Representative Present:</b> None	<b>Exit Time:</b> 9:01 am

Construction Site Notes:

-No construction occurring at this time.

Yes	No	N/A	
X			All erosion and sediment control measures installed/constructed
x			All erosion and sediment control measures maintained properly
	X		Are there currently more than 5 acres disturbed w/o prior approval
x	x		Have stabilization measures been initiated in inactive areas
x			Are permanent stormwater control measures being implemented
	X		Was there a discharge into the receiving water on the day of inspection
	X		Evidence of turbidity or oil in the receiving waters
x			Are weekly inspections being performed?
x			Are the inspections being performed by a qualified individual?

Corrections Needed:

-Stabilization of the yard of the house for sale is required.

Satisfactory                      Marginal                      X                      Unsatisfactory

**Date** 6-10-20

**Inspector** *Jessica Verrigni*



**COUNTY OF CHEMUNG**  
**Chemung County Stormwater Coalition**  
**851 Chemung Street**  
**Horseheads, New York 14825**  
**Ph. 607.796.2216**

**PROJECT:** Hunter's Run  
Town of Horseheads  
Municipal Inspection  
June 10, 2020

**BY:** Jessica Verrigni, CPESC, CPSWQ



Stabilization with perennial vegetation required.  
Weeds are not perennial vegetation.

