

**Chemung County Stormwater
Construction Inspection
Erosion and Sediment Control**



Project Name Hunter's Run	Date 4-11-22
Location Steeple Chase Horseheads, NY	Permit # NYR11F984
Weather Conditions sunny	Entry Time: 11:56 am
On-Site Representative Present:	Exit Time: 12:03 pm

Construction Site Notes:			
No lots under construction.			

Yes	No	N/A		
X			All erosion and sediment control measures installed/constructed	
X			All erosion and sediment control measures maintained properly	
	X		Are there currently more than 5 acres disturbed w/o prior approval	
X	X		Have stabilization measures been initiated in inactive areas	See Note
X			Are permanent stormwater control measures being implemented	
	X		Was there a discharge into the receiving water on the day of inspection	
	X		Evidence of turbidity or oil in the receiving waters	
X			Are weekly inspections being performed?	
			Are the inspections being performed by a qualified individual?	

Corrections Needed:			
-Soil stabilization required at the rear of the property by Lots 31 + 39. No earth moving equipment is on site so these areas are not being actively worked.			

Satisfactory	Marginal	x	Unsatisfactory
Date 4/11/22	Inspector Joshua Kerrigri		




COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14845
Ph. 607.796.2216

PROJECT: Hunter's Run
Town of Horseheads
Municipal Inspection
April 11, 2022

BY: Jessica Verrigni, CPESC, CPSWQ



Grass is starting to grow and catch basin protection installed and functioning.



Straw over bare soil.



Areas at the rear of the property by Lots 39 and 31 require stabilization.



Areas at the rear of the property by Lots 39 and 31 require stabilization.