



Project Name UHAUL	Date 8-25-16
Location State Route 14 Horseheads, NY	Permit #NYR11A438
Weather Conditions <i>overcast, warm</i>	Entry Time: <i>11:03</i>
On-Site Representative Present: Larry Crooker, Welliver	Exit Time: <i>11:37</i>

Construction Site Notes:

- Site is waiting for DEC approval on disposal of fill material (foundry sand).
- Have experienced water issues from off site stream. Water has no channel and comes onto property.
- New concrete washout installed. Pouring 8/31 on building at south end of project.

Yes	No	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All erosion and sediment control measures installed/constructed
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All erosion and sediment control measures maintained properly <i>make silt fence repairs Adam noted.</i>
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Are there currently more than 5 acres disturbed w/o prior approval
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Have stabilization measures been initiated in inactive areas
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are permanent stormwater control measures being implemented
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Was there a discharge into the receiving water on the day of inspection
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Evidence of turbidity or oil in the receiving waters
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are weekly inspections being performed?
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are the inspections being performed by a qualified individual?

Corrections Needed:

- Issues that have come up regarding off site drainage are being dealt with through Marathon Engineers.

Satisfactory <input checked="" type="checkbox"/>	Marginal <input type="checkbox"/>	Unsatisfactory <input type="checkbox"/>
Date <i>8/25/16</i>	Inspector <i>Josuea Verriigni</i>	



**COUNTY OF CHEMUNG**  
**Chemung County Stormwater Coalition**  
**851 Chemung Street**  
**Horseheads, New York 14825**  
**Ph. 607.796.2216**

**PROJECT:** UHaul  
Town of Horseheads  
Municipal Construction Inspection  
August 25, 2016

**BY:** Jessica Verrigni, CPESC, CPSWQ



Concrete washout area.



Sediment Barrier has been installed.



Construction entrance has been installed.



Area where water is coming onto the site.  
Consultant has developed a plan to address this.