

Website Updated:
 Active Construction List Updated

Chemung County Stormwater
 Construction Inspection
 Erosion and Sediment Control



Project Name UHAUL	Date 5-11-17
Location State Route 14 Horseheads, NY	Permit #NYR11A438
Weather Conditions Overcast	Entry Time: 9:53
On-Site Representative Present: Larry Crooker, Welliver	Exit Time: 10:16

Construction Site Notes:

-Working on stormwater bioretention (south end)

Yes	No	N/A	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All erosion and sediment control measures installed/constructed
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All erosion and sediment control measures maintained properly
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Are there currently more than 5 acres disturbed w/o prior approval
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Have stabilization measures been initiated in inactive areas
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are permanent stormwater control measures being implemented
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Was there a discharge into the receiving water on the day of inspection
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Evidence of turbidity or oil in the receiving waters
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are weekly inspections being performed?
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Are the inspections being performed by a qualified individual?

Corrections Needed:

-no issues at this time.

Satisfactory Marginal Unsatisfactory

Date **5/11/17** Inspector **Jessica Verrigni**



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: UHaul
Town of Horseheads
Municipal Construction Inspection
May 11, 2017

BY: Jessica Verrigni, CPESC, CPSWQ



Drop inlet being brought up to grade.



Excess concrete disposed of improperly.



Silt fence functioning.



Bioretention on south end of property under construction



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: UHaul
Town of Horseheads
Municipal Construction Inspection
May 11, 2017

BY: Jessica Verrigni, CPESC, CPSWQ



Bioretention under construction.



Outlet of bioretention on south end of property.



Roof drain (on existing building) not connected to system.



Roof drain (on existing building) not connected to system.