






COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216

PROJECT: UHaul  
Town of Horseheads  
Municipal Construction Insp.  
June 26, 2017

BY: Jessica Verrigni, CPESC, CPSWQ



Area next to Building B does not appear to have been topsoiled, had soil restoration performed and has not been stabilized.



Roof runoff from building b is creating an erosion issue into the detention pond.



Erosion into the detention pond. Detention pond does not appear completed.



Rock slope protection has not been installed on the slope of north bioretention basin.



COUNTY OF CHEMUNG  
Chemung County Stormwater Coalition  
851 Chemung Street  
Horseheads, New York 14825  
Ph. 607.796.2216

<b>PROJECT:</b>	<u>UHaul</u>
	<u>Town of Horseheads</u>
	<u>Municipal Construction Insp.</u>
	<u>June 26, 2017</u>
<b>BY:</b>	Jessica Verrigni, CPESC, CPSWQ



Blacktop piles can be found thrown onto the graded areas around the project site. These need to be cleaned up.



Paint brushes were being washed onto the new pavement at the time of my visit. I stopped it and spoke with the store manager about it.

