



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT: UHaul
Town of Horseheads
Municipal Inspection
July 18, 2017

BY: Jessica Verrigni, CPESC, CPSWQ



Rock slope protection has not been installed.



Silt Sack will need to be removed from this structure.



Slight erosion and sedimentation is creeping towards the bioretention from unfinished basin.



Unfinished stormwater basin. Erosion is occurring off the back of building b into the basin.



COUNTY OF CHEMUNG
Chemung County Stormwater Coalition
851 Chemung Street
Horseheads, New York 14825
Ph. 607.796.2216

PROJECT:	UHaul
	Town of Horseheads
	Municipal Inspection
	July 18, 2017
BY:	Jessica Verrigni, CPESC, CPSWQ



Erosion into unfinished stormwater basin.

