

Chemung County Department of Health
Environmental Health Services
103 Washington Street P. O. Box 588, Elmira, NY 14902-0588
(607) 737 - 2019
EHS@co.chemung.ny.us
Temporary Residence Inspection -- Summary Report

Operation: FAIRFIELD INN & SUITES (ID: 817265)
Facility Name: FAIRFIELD INN & SUITES
Facility Code: 07-4675 Facility Email: None
Facility Address: 1600 COUNTY ROUTE 64 HORSEHEADS, NY 14845

To the Attention of:
HEMANT PATEL HORSEHEADS LODGING GROUP, LLC
DBA - FAIRFIELD INN & SUITES 1600 COUNTY ROUTE 64
HORSEHEADS , NY 14845- Owner/Operator Email: tmagnusen@visions-hotels.com

Inspection
Date: SEP 14, 2017 11:40 AM
Inspector: Erin Walmsley (ewalmsley@co.chemung.ny.us)
Responsible Person: emailed to operator
(email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

FACILITY MISCELLANEOUS

ITEM # 38 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Housing maintenance: structurally sound, adequate illumination/ventilation, size, health/safety hazards absent, weather tight roof/sides {7-1.15}

Inspector Findings

Observed water leaking down wall over door frame and onto floor from pipe in boiler room. Manager indicated that leak has been identified and time table of correction has been established for 9/28/17

Additional Information Collected During Inspection

Comments

Observed rooms 102, 214 and 230. Observed maid carts as well as maintenance rooms, electrical rooms, linen closet and laundry rooms. Reviewed fire safety plan and observed functional Alarm Panel.

END of REPORT

[Submit# 326072] FAIRFIELD INN & SUITES (ID 817265) Inspection# 1002199830