

Chemung County Department of Health  
Environmental Health Services  
103 Washington Street P. O. Box 588, Elmira, NY 14902-0588  
(607) 737 - 2019  
EHS@co.chemung.ny.us

Institutional Food Service Inspection -- Summary Report

Operation: DIVEN SCHOOL CAFETERIA (ID: 265526)  
Facility Name: DIVEN SCHOOL  
Facility Code: 00380-09 Facility Email: None  
Facility Address: 1115 HALL STREET ELMIRA, NY 14901

To the Attention of:  
KARI CROUSE ELMIRA CITY SCHOOL DISTRICT  
C/O - ELMIRA H.S. (Attn: K. CROUSE) 777 S. MAIN ST.  
ELMIRA , NY 14904- Owner/Operator Email: kcrouse@gstboces.org

Field Visit

Date: MAR 02, 2017 01:00 PM  
Inspector: Michael Cain (mcain@co.chemung.ny.us)  
Responsible Person: Copy of field visit report was sent via e-mail to Kari Crouse, Elmira City School Dist.  
(email: )

Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Comments

Conducted a field visit to facility to check on temperature of cold water kitchen sink taps. Meet with Mike Dunn, Elmira City School District Maintenance Supervisor and plumbing staff, was accompanied by Jon Keough, Supervising Sanitarian. Checked cold water temperature at kitchen 3-bay sink- was 61 degrees F via thermocouple-Corrected from previous inspection report of 2-16-17. Plumbers indicated issue was caused by bleeding of hot water, due to high pressure, into cold water line. New valves were installed on cold water distribution line so that the hot water does not impact the cold water temperature. It was suggested that the hot water temperature be adjusted (reduced) slightly since the dish machine already has its own booster tank. Plumbers will make an adjustment this week. Sanitarian will recheck kitchen sink temperatures the week of March 6, 2017, or later.

END of REPORT

[Submit# 270695] DIVEN SCHOOL CAFETERIA (ID 265526) Inspection# 1001946318