

Chemung County Department of Health
Environmental Health Services
103 Washington Street P. O. Box 588, Elmira, NY 14902-0588
(607) 737 - 2019
EHS@co.chemung.ny.us

Institutional Food Service Inspection -- Summary Report

Operation: DIVEN SCHOOL CAFETERIA (ID: 265526)
Facility Name: DIVEN SCHOOL
Facility Code: 00380-09 Facility Email: None
Facility Address: 1115 HALL STREET ELMIRA, NY 14901

To the Attention of:
KARI CROUSE ELMIRA CITY SCHOOL DISTRICT
C/O - ELMIRA H.S. (Attn: K. CROUSE) 777 S. MAIN ST.
ELMIRA , NY 14904- Owner/Operator Email: kcrouse@gstbores.org

Field Visit

Date: MAR 09, 2017 10:46 AM
Inspector: Michael Cain (mcain@co.chemung.ny.us)
Responsible Person: Copy of field visit was sent via e-mail to Kari Crouse, Elmira City School District on 3-9-17.
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

IMPROPER SANITARY FACILITIES AND CONTROLS.

ITEM # 12C WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Plumbing and sinks not properly sized, installed, maintained; equipment and floors not properly drained

Inspector Findings

At 11:05 AM, conducted a follow-up field visit to facility to recheck both cold and hot water temperatures at kitchen sink taps. Rechecked kitchen 3-bay sink, employee hand wash sink, and single-bay sink located at center kitchen counter. Initial cold water temperatures from each of these sink taps was found at 70 degrees F using thermocouple which increased to 90-92 degrees F as sink tap was allowed to run for approximately 1 minute. Cold water temperature then gradually dropped back to 63 degrees F after running for approx. 5 minutes where it stabilized in the low 60 degree F range. Also, checked hot water temperatures at each of these sinks. Initial hot water temperatures were observed in the low 90 degree F range but quickly increased to 133 degrees F within 30 seconds where it stabilized in the low 130 degree F range.

Additional Information Collected During Inspection

Comments

Discussed findings with Samantha Kelsey, Kitchen Manager during field visit.

END of REPORT

[Submit# 272263] DIVEN SCHOOL CAFETERIA (ID 265526) Inspection# 1001948137