

Chemung County Department of Health  
Environmental Health Services  
103 Washington Street P. O. Box 588, Elmira, NY 14902-0588  
(607) 737 - 2019  
EHS@co.chemung.ny.us

Institutional Food Service Inspection -- Summary Report

Operation: DIVEN SCHOOL CAFETERIA (ID: 265526)  
Facility Name: DIVEN SCHOOL  
Facility Code: 00380-09 Facility Email: None  
Facility Address: 1115 HALL STREET ELMIRA, NY 14901

To the Attention of:  
KARI CROUSE ELMIRA CITY SCHOOL DISTRICT  
C/O - ELMIRA H.S. (Attn: K. CROUSE) 777 S. MAIN ST.  
ELMIRA , NY 14904- Owner/Operator Email: kcrouse@gstbooces.org

Field Visit

Date: MAY 30, 2017 01:10 PM  
Inspector: Michael Cain (mcain@co.chemung.ny.us)  
Responsible Person: A copy of inspection report was sent via e-mail to Kari Crouse and Mike Dunn, Main.  
Superintendent

(email: )

Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Comments

Made field visit to recheck hot and cold water temperatures at kitchen sink taps. Was accompanied by Bob McCarick, Maintenance Dept. At 1:10 PM, checked both cold and hot water temperatures at kitchen 3-bay sink (warewashing), 2-bay sink (warewashing) and single-bay sink (handwashing sink) located at center counter. The temperatures at all three of these kitchen sinks were consistent when checked using a thermocouple. The cold water taps were initially at low 70 degree range when turned-on but quickly dropped to 65-66 degrees F within 30 seconds. The hot water started out in the low 80 degree F range but quickly increased to 130 degrees F within 30 seconds. Bob McCarick provided an overview of recent equipment changes, alterations, and installations, on the water system. Recommended to maintenance staff that they check both hot and cold water temperatures in the kitchen over the summer and prior to school reopening in September. The blue-item violation # 12C from previous inspection report of April 10, 2017 has been corrected.

END of REPORT

[Submit# 289189] DIVEN SCHOOL CAFETERIA (ID 265526) Inspection#

1001970775