

Chemung County Department of Health
Environmental Health Services
103 Washington Street P. O. Box 588, Elmira, NY 14902-0588
(607) 737 - 2019
EHS@co.chemung.ny.us

Food Service Establishment Inspection -- Summary Report

Operation: ELMIRA DRIVE IN (ID: 265375)
Facility Name: ELMIRA DRIVE-IN (Seasonal)
Facility Code: 00339-01 Facility Email: None
Facility Address: 2417 STATE ROUTE 352 BIG FLATS, NY 14814

To the Attention of:
CONRAD ZURICH ZURICH DRIVE-IN CORP.
ATTN: CONRAD ZURICH 5181 BROCKWAY LANE
FAYETTEVILLE , NY 13066- Owner/Operator Email: zurich00@twcny.rr.com

Pre-op Inspection
Date: APR 05, 2017 10:33 AM
Inspector: Zachary Cavaluzzi (zcavaluzzi@co.chemung.ny.us)
Responsible Person: Alex Miller
(email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Comments

No violations observed during time of preoperational inspection. All items from previous field visit, 8A - single use food items stored on floor, 12C - sink missing in women's toilet room and leak in pipe in men's toilet room, and 15B - unshielded lightbulbs above prep table in kitchen and above candy display area have been corrected. Waiting results of previously submitted water sample and for operator to complete start-up procedure certification form for facility's private water supply prior to permit issuance.

END of REPORT

[Submit# 277859] ELMIRA DRIVE IN (ID 265375) Inspection# 1001955698