

Chemung County Department of Health
Environmental Health Services
103 Washington Street P. O. Box 588, Elmira, NY 14902-0588
(607) 737 - 2019
EHS@co.chemung.ny.us

Food Service Establishment Inspection -- Summary Report

Operation: THE PEPPER POT CAFE (ID: 962582)
Facility Name: PEPPER POT CAFE, The
Facility Code: 01110-01 Facility Email: None
Facility Address: 311 COLLEGE AVENUE ELMIRA, NY 14901

To the Attention of:
TAMI MARRONE PEPPERPOT CAFE LLC
311 COLLEGE AVE
ELMIRA , NY 14901- Owner/Operator Email: tamirae74@yahoo.com

Re-Inspection
Date: SEP 18, 2017 02:45 PM
Inspector: Michael Cain (mcain@co.chemung.ny.us)
Responsible Person: Tami Marrone, Operator
(email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

IMPROPER SANITARY FACILITIES AND CONTROLS.

ITEM # 12C WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Plumbing and sinks not properly sized, installed, maintained; equipment and floors not properly drained

Inspector Findings

Basement- wastewater line at indirect drain near ice machine is leaking into plastic basin- Operator contacted plumber during re-inspection.

Additional Information Collected During Inspection

Comments

A revised Time Table of Compliance Date of September 30, 2017 has been established to correct leaking wastewater line in basement. A re-inspection will be conducted on or after this date to determine compliance.

END of REPORT

[Submit# 326883] THE PEPPER POT CAFE (ID 962582) Inspection# 1002200655