

Chemung County Department of Health
Environmental Health Services
103 Washington Street
P. O. Box 588
Elmira, NY 14902-0588
(607) 737-2019
EHS@co.chemung.ny.us

Food Service Establishment Inspection Summary Report

Operation: DOWNTOWN GRIND (ID: 1009222)
Facility Name: DOWNTOWN GRIND
Facility Code: 01329-01
Facility Address: 109 North Main Street, Elmira, NY 14901

To the Attention of:

Sara Caldwell
209 Montour St.
Montour Falls, NY 14865
Email: downgrindelmira@gmail.com

Pre-op Inspection

Date: November 19, 2018 09:00 AM
Inspector: Michael Cain (mcain@co.chemung.ny.us)
Responsible Person: Sara Caldwell, Operator

Summary

Number of Public Health Hazards Found:	0
Number of Public Health Hazards NOT Corrected:	0
Number of Other Violations Found:	0

Each item found in violation is reported below along with the code requirement.

NO CRITICAL VIOLATIONS REPORTED

NO ADDITIONAL VIOLATIONS REPORTED

Additional Information Collected During Inspection

Comments: Conducted pre-operational inspection of facility on 11-19-18. Operator provided copy of Worker's Compensation form during pre-op. inspection, other fse paperwork was previously submitted to HD including fse application, fee & copy of Disability Insurance form. Certificate of Occupancy was issued by City of Elmira Code Enforcement Officer on 11-15-18 (copy is posted on wall behind counter). Reviewed food handler's quiz with Operator during pre-operational inspection. Operator has corrected items from preliminary walk-thru assessment including- Lower storage shelving and stairwell storage shelving have been painted, soap & hand towel dispenser installed at front counter hand sink, rest room doors installed w/ self-closing hinges, covered receptacle installed in women's rest room for sanitary products, air gap installed on kitchen 3-bay sink which will be used for vegetable/ produce washing, section of 4" in. cove molding installed near kitchen hand wash sink. Will conduct an operational inspection in near future.



Inspector: Michael Cain (mcaïn@co.chemung.ny.us)



Received by: Sara Caldwell, Operator