

Chemung County Department of Health
Environmental Health Services
103 Washington Street P. O. Box 588, Elmira, NY 14902-0588
(607) 737 - 2019
EHS@co.chemung.ny.us
Temporary Residence Inspection -- Summary Report

Operation: LIGHT ON THE HILL (ID: 519257)
Facility Name: LIGHT ON THE HILL
Facility Code: 07-4600 Facility Email: None
Facility Address: 209 BLAKE HILL ROAD VAN ETTEN, NY 14889

To the Attention of:
LAWRENCE MUSCAT LIGHT ON THE HILL, INC.
ATTN: LAWRENCE MUSCAT 209 BLAKE HILL RD.
VAN ETTEN , NY 14889- Owner/Operator Email: Not Sent

Inspection
Date: OCT 26, 2018 02:18 PM
Inspector: Erin Walmsley (ewalmsley@co.chemung.ny.us)
Responsible Person: Mark Karlsen
(email: info@lightonthehill.org)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

FIRE SAFETY

ITEM # 26 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Fire extinguishers: conspicuous location/accessible, maintenance documentation available on-site {7-1.8(c)}

Inspector Findings

Monthly fire extinguisher checks have not been completed since August 2018. Operator to complete monthly check for month of October.

Additional Information Collected During Inspection

Comments

Observed functional emergency lights and illuminated exit signs. Observed laundry rooms, restrooms, and boiler rooms. Facility has a group staying in rooms at time of visit. Observed UV light system- operator stated light is scheduled to be changed in November 2018.

END of REPORT

[Submit# 455664] LIGHT ON THE HILL (ID 519257) Inspection# 1002384447