

## Campground Inspection Summary Report

Operation: CHEMUNG COUNTY FAIRGROUNDS (ID: 265020 )  
Facility Name: CHEMUNG COUNTY FAIRGROUNDS  
Facility Code: 07-2464  
Facility Address: 170 Fairview Road, Horseheads, NY 14845

### To the Attention of:

Don Bishop  
COUNTY OF CHEMUNG  
Buildings & Grounds (d. Bishop)  
217 Madison Ave. (interdept)  
Elmira, NY 14901  
Email: dbishop@chemungcountyny.gov

### Pre-op Inspection

Date: April 28, 2021 02:31 PM  
Inspector: Zachary Brueckman (zbrueckman@chemungcountyny.gov)  
Responsible Person: Emailed To Operator

### Summary

Number of Public Health Hazards Found:	0
Number of Public Health Hazards NOT Corrected:	0
Number of Other Violations Found:	2

---

*Each item found in violation is reported below along with the code requirement.*

## NO PUBLIC HEALTH HAZARDS REPORTED

---

### GENERAL

#### ITEM #22 WAS FOUND IN VIOLATION 1 TIME(S).

*All or parts of the item are violations.*

**Code Requirements:** Electrical service; wiring and fixtures installed, maintained {7-3.17}

**Inspector Findings:**

- 1.No water proof cover on the following electrical receptacles: Horse Barn 11; stables A1, B3, J2, L3, L8, K8. Barn 18; between stables 10 and 11.
2. GFI test buttons inoperable through fairground buildings.

---

## WATER SUPPLY - GENERAL

### ITEM #40 WAS FOUND IN VIOLATION 1 TIME(S).

*All or parts of the item are violations.*

**Code Requirements:** Campground Public Water System - complies w/ Subpart 5-1 {7-3.13}

**Inspector Findings:** Hose bibs missing from water sources on lots 97, 98, 99, 100.

---

### Additional Information Collected During Inspection

**Comments:** Observed undercharged fire extinguisher in Horse Barn 11. All extinguisher in fairgrounds were last inspected June 2020. Free chlorine residual at 24 hour bathroom mop sink (Building 16, Area 2) was .4 mg/L. Bathrooms unavailable for inspection due to COVID restrictions.

---



---

Inspector: Zachary Brueckman  
(zbrueckman@chemungcountyny.gov)